



ALSO SEE GENERAL NOTES & SPECIFICATIONS.
ALL EXISTING/REWORK ELECTRICAL COMPONENTS & SYSTEMS SHALL COMPLY TO THE 2021 CANADIAN ELECTRICAL CODE, PART I, 25TH EDITION (NOTED AS "CODE") ADOPTED BY THE WINNIPEG ELECTRICAL BY-LAW NO. 72/2022. THIS INCLUDES ABANDONED WIRES, CABLES, CONDUITS & ITS SUPPORTS SHALL BE REMOVED.
DO NOT DISTURB OR DISCONNECT ANY WIRING & CABLING IN AREA OF WORK REQUIRED FOR OTHER AREAS.

1. REPLACE ELECTRIC SERVICE LINE-SIDE AS PER SLD & RENOVATION DRAWINGS.
2. REPLACE ALL ELECTRICAL PANELS & CIRCUIT BREAKERS AS SHOWN, EXCEPT PANEL "SUB-J" SHALL BE REMOVED & RE-CIRC AS PER SLD DRAWING.
3. REPLACE REVERSE-FED TRANSFORMER , SEE RENO DRAWING.
4. REPLACE LUMINAIRES, LIGHT SWITCH & FACEPLATE, SEE RENO DRAWING.

1	ISSUED FOR ADDENDUM 3	DTA	10.14 2025
0	ISSUED FOR CONSTRUCTION	DTA	09.11 2025
A	ISSUED FOR REVIEW	DTA	08.15 2025
No.	REVISION/DESCRIPTION	BY	DATE

DATE	DESIGN	DRAWN	CHECKED	APPROVED
2025.08.08	BY: DTA	BY: DTA	BY:	BY:



SHEET TITLE
BASEMENT FLOOR PLAN
ELECTRICAL - DEMOLITION
POWER AND SYSTEMS

SCALE AS SHOWN	PROJECT No: 2024-070	SHEET No: E2-R1
-------------------	-------------------------	---------------------------