



519-2026 ADDENDUM 2

GOULET-DOUCET WATER MAIN RIVER CROSSING REHABILITATION

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: July 27, 2026
BY: Matt Krentz, C.E.T.
TELEPHONE NO. 431 336-5586

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Addendum 2026-03-10

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART E – SPECIFICATIONS

- | | | |
|------|------------|--|
| Add: | E15.4.8 | Liner Venting |
| Add: | E15.4.8(a) | Install 25 mm diameter liner vents in asbestos-cement host pipe as recommended by FFRP liner manufacturer. |
| Add: | E15.4.8(b) | Connection saddle or tapping sleeve shall be to City of Winnipeg specifications. |