



ADDENDUM NO. 1 BID OPPORTUNITY NO. 160-2004

Construction of a 150mm Residential Sewer Service at 2776 Assiniboine Avenue and a Packaged Duplex Sewage Pumping System and 50MM Low Pressure Sewer Service to 2782 Assiniboine Avenue

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: April 14, 2004
BY: Coleen Groening /ht
TELEPHONE NO. (204) 986-2491

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: 20040128

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid Submission non-responsive.

PART A – BID SUBMISSION

Revise: Form B: Prices, Item A.4

Further to Item A.4 of Form B: Prices "Connecting to Existing Sewer" and CW 2130-R7, the existing 600mm diameter sewer is believed to be vitrified clay, the Contractor will be allowed to connect by coring a hole by an approved method and installing an "Inserta-Tee" or approved equal or saddle held in place with stainless steel straps.

Revise: Form B: Prices, Item B.3

Further to Item B.3 of Form B: Prices "Connecting to Existing Sewer" and CW 2130-R7 the existing sewer is believed to be 1200mm x 800mm concrete, the Bidder is advised to confirm this information in the field.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read:

B2.1 The Submission Deadline is 12:00 noon Winnipeg time, **April 20, 2004**.