



ADDENDUM NO. 2 BID OPPORTUNITY NO. 160-2004

Construction of a 150mm Residential Sewer Service at 2776 Assiniboine Avenue and a Packaged Duplex Sewage Pumping System and 50MM Low Pressure Sewer Service to 2782 Assiniboine Avenue

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: April 15, 2004
BY: Coleen Groening /clg
TELEPHONE NO. (204) 986-2491

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: 20040128

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid Submission non-responsive.

PART A – BID SUBMISSION

Revise: Form B:, Item B.2

Further to Item B.2 of Form B: Prices "Plugging existing sewers & sewer connections" and CW 2130-R7 the existing sewer service is to be plugged at a point inside the building using an approved mechanical plug and also plugged from inside the existing outfall sewer if man-entry is possible. No excavation will be required to plug and abandon the service.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read:

B2.1 The Submission Deadline is 12:00 noon Winnipeg time, **April 22, 2004**.

PART E – SPECIFICATIONS

Further to E3, the Bidder shall assume that the existing electrical panel is suitable for the electrical requirements of the PDSPS. The Contractor is responsible for supplying and installing all electrical plant required for the PDSPS and shall be included in the price bid for "Supply and Installation of Packaged Duplex Sewage Pumping System".