



ADDENDUM NO. 1 BID OPPORTUNITY NO. 185-2004

ROBSON/ATWOOD PARK – SITE REDEVELOPMENT

ISSUED: July 28, 2004
BY: Coleen Groening /clg
TELEPHONE NO. (204) 986-2491

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: 20040128

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid Submission non-responsive.

PART A – BID SUBMISSION

Replace: Form B: Prices with Form B: Prices (R1)

PART E – SPECIFICATIONS

Revise: E11 to read:

E11 PLAYGROUND STONE SAFETY BASE

E11.1 General Description

E11.1.1 This Specification shall cover supply and installation of Playground Stone Safety Base as shown on the Drawings.

E11.1.2 The Work to be done by the Contractor under this Specification shall include the furnishing of all superintendence, overhead, labour, materials, equipment, tools, supplies, and all other things necessary for and incidental to the satisfactory performance and completion of all Work as specified herein.

E11.1.3 All materials supplied under this Specification shall be of a type approved by the Contract Administrator and shall be subject to inspection and testing by the Contract Administrator.

E11.2 Materials

E11.2.1 Materials

Playground stone shall be 6.35mm typical Birds Hill glacial till, approximately 70% limestone and 30% granite. Stone shall be washed and screened.

Sieve Analysis:

<u>Sieve Size</u>	<u>Cumulative % Passing</u>
10mm	100
5mm	80
2.5mm	5-10
1.25mm	2-6
.08mm	0-1

E11.3 Equipment

E11.3.1 All equipment shall be of a type approved by the Contract Administrator and shall be kept in good working order.

E11.4 Construction Method

E11.4.1 The Installation of playground stone shall be done immediately after the play structures have been installed. Installation shall be done by equipment sized to suit the work being done and the stone shall be spread by hand in the immediate vicinity of the play structures so as not to damage the same. The play structures shall be swept clean as required after installation of the stone.

E11.4.2 Clear subgrade of all debris and compact subgrade.

E11.4.3 Obtain approval of compacted subgrade prior to stone installation.

E11.4.4 Coordinate stone installation with play equipment installation.

E11.4.5 Spread playground stone to 250mm depth. Rake smooth for an even surface.

E11.5 Construction Method for Existing Play Area

E11.5.1 Remove existing sand and excavate as required for the correct depth of stone (225mm). Do the work manually around existing play equipment to avoid damaging it. Any damage to the equipment must be made good.

E11.6 Method of Measurement

E11.6.1 The supply and installation of Playground Stone Safety Base shall be measured on a Volume Basis. The area to be paid for shall be the total number of cubic meters installed in accordance with this Specification and accepted by the Contract Administrator, as calculated from measurements made by the Contract Administrator.

E11.7 Basis of Payment

E11.7.1 The supply and installation of Playground Stone Safety Base shall be paid for at the Contract Unit Price per cubic metre for "Playground Stone Safety Base", measured as specified herein, which price shall be payment in full for supplying all materials and performing all operations herein described and all other items incidental to the Work included in this Specification.

Revise E16.7.13 to read:

E16.7.13 Substitutions to plant material as indicated on planting plan are not permitted unless written approval has been obtained as to type, variety and size. Plant substitutions must be of similar species and of equal size as those originally specified.