



ADDENDUM NO. 1 BID OPPORTUNITY NO. 410-2004

HVAC UPGRADES ZOO HOSPITAL – 15 COMMISSARY DRIVE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: August 23, 2004
BY: Menno Sawatsky /c
TELEPHONE NO. (204) 986-7286

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: 20040128

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid Submission non-responsive.

PART E – SPECIFICATIONS

Add: E3.8 to read:

E3.8 EF #8 to be Greenheck G-085-D c/w back draft damper, roof mounted exhaust fan or equal. The return air grilles to be as specified in E3.4.

PART E – SPECIFICATIONS

Replace: Drawing M2-R0 with Drawing M2-R1.