



## **ADDENDUM NO. 1 BID OPPORTUNITY NO. 477-2004**

**Sewer Cleaning and Inspection – Baltimore and Douglas Park Combined  
Sewer Districts - Contract 22**

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: October 15, 2004  
BY: Paula Kreitz  
TELEPHONE NO. (204) 453-2301

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20040901

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid Submission non-responsive.**

---

### **PART E – SPECIFICATIONS**

Revise E3.3 to read:

- E3.3 Further to CW 2140, clauses 3.1, 3.2, 3.5 and 3.11, removal of grease shall be considered part of "Sewer Cleaning" and will not be considered for payment under "Solid Debris Removal".
- E3.3.1 All grease deposits greater than ten percent (10%) of the cross sectional area of the pipe shall be removed.
- E3.3.2 The Contractor will not be required to remove grease deposits under ten percent (10%) of the cross sectional area provided that a reasonable amount of effort has been made to clean the pipe.