



# ADDENDUM 1 BID OPPORTUNITY NO. 515-2005

## WINNIPEG WATER TREATMENT PROGRAM – SUPPLY OF RAW WATER PUMPS

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: October 5, 2005  
BY: Bill Richert, P. Eng.  
TELEPHONE NO. (204) 986-6053

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20050301

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

### **PART E – SPECIFICATIONS**

#### **Section 11320a**

Revise: 1.2.12 to read: Minimum available net positive suction head (NPSH): 12.5 metres.