



## **ADDENDUM 2 BID OPPORTUNITY NO. 515-2005**

### **WINNIPEG WATER TREATMENT PROGRAM – SUPPLY OF RAW WATER PUMPS**

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: October 7, 2005  
BY: Bill Richert, P. Eng.  
TELEPHONE NO. (204) 986-6053

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20050301

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART A – BID SUBMISSION**

Replace: Part A – Bid Submission with 515-2005\_Addendum\_2-Bid\_Submission  
(Form G2 has been replaced by Form G2(R1))

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, October 19, 2005.

#### **PART E – SPECIFICATIONS**

##### **Section 11320a**

- Revise: 1.2.14 to read: Discharge water elevation at the DAF tank (m): 244.3.
- Revise: 1.3.7 to read: Normal design flow pump head [total dynamic head (TDH) m]: 4.9.
- Revise: 1.3.9 to read: Maximum design flow pump head (TDH m): 6.8.
- Revise: 1.3.11 to read: Special operating design flow pump head (TDH m): 10.1.