



Corporate Finance Department  
Materials Management Division

## **ADDENDUM NO. 1 BID OPPORTUNITY NO. 52-2005**

### **2005 MAGER DRIVE WASTEWATER PUMPING STATION EXPANSION**

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: February 24, 2005  
BY: T. Whiteside  
TELEPHONE NO. (204) 986-4451

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20041223

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART A – BID SUBMISSION**

Replace: Form B: Prices with Form B(R1): Prices

#### **PART B – BIDDING PROCEDURES**

Delete: B9.1.1

#### **PART D – SUPPLEMENTAL CONDITIONS**

Revise: D14.2 (a)(vi) to read: the detailed prices specified in D10;

#### **PART E – SPECIFICATIONS**

Revise: E14.2.3 to read: Grout shall be Sika Grout 212, CPD Non-Shrink Grout or approved equal.

Revise E14.2.12 (a) to read: Board insulation: expanded polystyrene board to CAN/ULC-S701, Type 4, thickness as indicated on Drawings, ship lapped edges, Dow "Styrofoam SM", "Celfort 300" or approved equal.

#### **DRAWINGS**

Please note the drawings issued for this Bid Opportunity require a large amount of printer memory and may need to be commercially printed.