



NOTES: 1. DUCT SMOKE DETECTOR: THIS IS A NONADDRESSABLE DEVICE, THEREFORE, MODULE 1105 MONITORS ALARM STATUS OF DETECTOR AND MODULE 1106 MONITORS POWER SUPPLY OF DETECTOR.

FORT ROUGE GARAGE BUILDING A ADMIN BUILDING FIRE ALARM SYSTEM	REVISION 2
	REF NO FRG_034
	DRAWING NO. FA004