



Boiler Room

- ① Existing York Turbopak Chiller
- ② SF 1 – Air Conditioning Unit
- ③ Smith – Commercial Water Heater
- ④ RBI – Gas Fired Water Boilers #1 and #2
- ⑤ Condenser and Chilled Water Pumps
- ⑥ SF 2 – Air Conditioning Unit, located in Mechanical Room
- ⑦ Cooling Tower for existing Chiller.
Location – on the roof of Machine Shop
- ⑧ New Air - Cooled Chilling System. Proposed location – East side of Administration Building

WINNIPEG TRANSIT DEPARTMENT 421 Osborne Street Winnipeg MB R3L 2A2 Tel: 986-3821 / 479-5430 avecherya@winnipeg.ca		
PROJECT		
YORK TURBOPAK CHILLER REPLACEMENT AT 421 OSBORNE STREET		
SHEET TITLE		
PLAN - LOCATION FOR EXISTING AND PROPOSED CHILLING SYSTEMS		
DRAWN BY	CHECKED BY	APPR. BY
AV		
eFILE	PROJECT No	
643-2005 <u>DRAWING A-1-RO</u>	643-2005	
DATE	SCALE	
2005. 11.26	NTS	
SHEET No		A-1