

PIPING SCHEDULE

Service	Commodity Abbreviation	Nominal Size(s) (mm)	Exposure ²	Piping Material ²	Specification Section	Test Type and Pressure (kPa) ¹	Remarks
Raw Water	RW	300, 450, 900	EXP	Epoxy coated/lined steel	15200-03	H, 500	Raw water supply to the WTP and Fire Water Supply.
Raw Water	RW	1350	EXP/SUB	Epoxy coated/lined steel	15200-04	H, 500	Raw water supply to the WTP.
Raw Water	RW	900	EXP/SUB	Epoxy coated/lined steel	15200-03	H, 120	Wet Well Access Manways
Sanitary Drain	DRA	75	EXP/ ENC	CI	15100-02	N/A	Test per requirement of Plumbing Code
Sump Pump Discharge	DRN	75	EXP/ BUR	Epoxy coated/lined steel	15200-03	H, 500	RWPS Valve Chamber
Trap Primer	TP	All	EXP/ BUR	COP	15200-13	H, 1000	Test per requirement of Plumbing Code
Notes							
1) H-Hydraulic; P-Pneumatic							
2) For pipe material and service exposure abbreviations, refer to Section 15200-00L.							