



UV MODULE 1A & 1B
 TYPE: MEDIUM PRESSURE HIGH INTENSITY
 BANKS: 2
 NO OF LAMPS: 168 PER BANK
 CAPACITY: 143 ML/d
 HEADLOSS @ MAX FLOW: 260 mm



B.M. ELEV.	EARTH TECH Earth Tech (Canada) Inc. Winnipeg, Manitoba 204-477-5081		ENGINEER'S SEAL ORIGINAL SIGNED BY D.J. TANIGUCHI FEB. 18/05	
DESIGNED BY: CGL	CHECKED BY: DT	APPROVED BY: DT	CONSULTANT DRAWING NO. 66303D-CP1.07	
1 ISSUED FOR ADDENDUM 1 05/03/11 ERC	2 ISSUED FOR TENDER 05/02/18 JEH	3 RELEASED FOR CONSTRUCTION BY: T. KJARTANSON	PROCESS UV CHANNEL 1 - MODULES 110/120	CITY FILE NUMBER
NO. REVISIONS	DATE	DATE 2004/11/03	DATE 2005-02-18	SHEET # OF #S
				CITY DRAWING NUMBER