



NOTES:

1. MINIMUM WL AT OUTFALL INLET IS LEVEL IMPOSED BY OUTFALL GEOMETRY TO CONVEY 380 ML/d.
2. MAXIMUM RIVER LEVEL SHOWN IS MAXIMUM RIVER LEVEL AT WHICH DISINFECTION CAN FUNCTION.



B.M. ELEV.	EARTH TECH		ENGINEER'S SEAL ORIGINAL SIGNED BY D.J. TANIGUCHI FEB. 18/05	THE CITY OF WINNIPEG Winnipeg WATER AND WASTE DEPARTMENT	
	Earth Tech (Canada) Inc. Winnipeg, Manitoba 204.477.5381			CITY FILE NUMBER	
	DESIGNED BY: CGL	CHECKED BY: DT			SHEET # OF #S
	DRAWN BY: KJW	APPROVED BY: DT		CITY DRAWING NUMBER	
HOR. SCALE: VERTICAL SCALE:		RELEASED FOR CONSTRUCTION BY: T. KJARTANSON	PROCESS HYDRAULIC PROFILE © 380 ML/d		
0	ISSUED FOR TENDER	05/02/18	JEH	DATE: 2004/11/03	DATE: 2005-02-18
CONSULTANT DRAWING NO. 66303D-CP1.02					