



UV MODULE 1A & 1B

TYPE: MEDIUM PRESSURE HIGH INTENSITY
 BANKS: 2
 NO OF LAMPS: 168 PER BANK
 CAPACITY: 143 ML/d
 HEADLOSS @ MAX FLOW: 260 mm



B.M. ELEV.	EARTH TECH Earth Tech (Canada) Inc. Winnipeg, Manitoba 204.477.5381		ENGINEER'S SEAL	THE CITY OF WINNIPEG Winnipeg WATER AND WASTE DEPARTMENT	
			DESIGNED BY: CGL		CHECKED BY: DT
			DRAWN BY: JD		APPROVED BY: DT
			ORIGINAL SIGNED BY: D.J. TANIGUCHI FEB. 18/05		
NO. REVISIONS: 0 ISSUED FOR TENDER: 05/02/18 DATE: 2004/11/03 BY: JEH		RELEASED FOR CONSTRUCTION BY: T. KJARTANSON DATE: 2005-02-18		CONSULTANT DRAWING NO. 66303D-CP1.07	
NEWPCC - SECONDARY EFFLUENT UV DISINFECTION FACILITY			CITY FILE NUMBER		
PROCESS UV CHANNEL 1 - MODULES 110/120			SHEET # OF #S		
			CITY DRAWING NUMBER		