



UV MODULE 3A & 3B
 TYPE: MEDIUM PRESSURE HIGH INTENSITY
 BANKS: 2
 NO OF LAMPS: 168 PER BANK
 CAPACITY: 143 ML/d
 HEADLOSS @ MAX FLOW: 260 mm



B.M. ELEV.	EARTH TECH <small>Earth Tech (Canada) Inc. Winnipeg, Manitoba 204.477.5381</small>		ENGINEER'S SEAL	THE CITY OF WINNIPEG Winnipeg WATER AND WASTE DEPARTMENT	
	DESIGNED BY: CGL	CHECKED BY: DT	ORIGINAL SIGNED BY: D.J. TANIGUCHI		
	DRAWN BY: KJW	APPROVED BY: DT	FEB. 18/05		
	HOR. SCALE: VERTICAL SCALE:		RELEASED FOR CONSTRUCTION BY: T. KJARTANSON		
0 ISSUED FOR TENDER	05/02/18	JEH	CONSULTANT DRAWING NO. 66303D-CP1.09	NEWPCC - SECONDARY EFFLUENT UV DISINFECTION FACILITY	
NO. REVISIONS	DATE	BY	DATE 2004/11/03	DATE 2005-02-18	PROCESS UV CHANNEL 3 - MODULES 310/320
				CITY FILE NUMBER	
				SHEET # OF #S	
				CITY DRAWING NUMBER	