


THIRD FLOOR PLAN
1:100

- NOTES:
1. CONSTANT VOLUME VENTURI VALVE BY E.H. PRICE, MODEL MA-CV SIZE 200. ADJUST FOR 118 L/S
 2. PROVIDE FIRE DAMPER AT ALL DUCT PENETRATION THRU FLOOR.
 3. PROVIDE DRIP LEG ON GAS PRES AS REQUIRED BY APPLICABLE GAS CODE.



<p>Certificate of Authorization CH2M HILL Canada Ltd. No. 1441 Expiry: April 30, 2007</p>		<p>Frederickson Cooper ARCHITECTS</p>		<p>Engineer's Seal ORIGINAL SIGNED BY D.K. CUDINGTON 2006/03/29</p>	
DESIGNED BY	TT	CHECKED BY	DL	CITY FILE NUMBER	
DRAWN BY	AM	APPROVED BY	AHL	SHEET OF	
NO. REVISIONS		DATE		CITY DRAWING NUMBER	
01	742-2005 ADDENDUM 5	06/06/19	TT	1-0601C-A-0103-001-010	
00	ISSUED FOR TENDER	06/03/29	SW		
		2005/07/04			
		2006/03/29			