




Rev.	Comments	Jumper or Internal Cable	Conductor #	Cable	Cable Information
0		Switch 1			
0		01	RJ-45	C-WTPSVR02-C01	4-Pair #24 AWG - Cat 5E TO WTPSVR02
0	Spare	02			
0	Spare	03			
0	Spare	04			
0	Spare	05			
0	Spare	06			
0	Plant Control Network Receive	PP1: 01 07-Rx			
0	Plant Control Network Transmit	PP1: 02 07-Tx			
0	Plant Control Network Receive	PP1: 14 08-Rx			
0	Plant Control Network Transmit	PP1: 13 08-Tx			
0		Switch 2			
0		01	RJ-45	C-WTPSVR02-C02	4-Pair #24 AWG - Cat 5E TO WTPSVR02
0		02	RJ-45	C-WTPSVHIS02-C01	4-Pair #24 AWG - Cat 5E TO WTPSVHIS02
0		03	RJ-45	C-WTPWSH32 01-C01	4-Pair #24 AWG - Cat 5E TO WTPWSH32 01
0	Spare	04			
0	Spare	05			
0	Spare	06			
0	Plant Monitoring Network Receive	PP1: 05 07-Rx			
0	Plant Monitoring Network Transmit	PP1: 06 07-Tx			
0	Plant Monitoring Network Receive	PP1: 18 08-Rx			
0	Plant Monitoring Network Transmit	PP1: 17 08-Tx			

NOTES:  <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.	 		ENGINEER'S SEAL	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION			
		DESIGNED BY	SWT	CHECKED BY			SWT	WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL
		DRAWN BY	SWT	APPROVED BY	AHL	AUTOMATION / I AND C PLANT COMMUNICATION CABLE TERMINATION DIAGRAMS	SHEET 19 OF 88 CITY DRAWING NUMBER 1-0601H-J-A0519-001-01B	
	1	742-2005 ADDENDUM 6	06/05/25	SWT	SCALE:	RELEASED FOR CONSTRUCTION BY:		
	0	ISSUED FOR TENDER	06/03/29	SWT	NTS	R. SOROKOWSKI		
	NO.	REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29
						2006/03/29		2006/03/29