




Rev.	Comments	Jumper or Internal Cable	Conductor #	Cable	Cable Information	
		PP1				
0	Plant Control Network Receive	Switch 1: 07-Rx	01	01	C-CP-J11A-C01 12-Strand 62.5/125 um Multi-mode TO LCP-T11A	
0	Plant Control Network Transmit	Switch 1: 07-Tx	02	02		
0	Remote I/O Network Receive	PP1: 15	03	03		
0	Remote I/O Network Transmit	PP1: 16	04	04		
0	Plant Monitoring Network Receive	Switch 2: 07-Rx	05	05		
0	Plant Monitoring Network Transmit	Switch 2: 07-Tx	06	06		
0	Spare		07	07		
0	Spare		08	08		
0	Spare		09	09		
0	Spare		10	10		
0	Spare		11	11		
0	Spare		12	12		
0	Plant Control Network Transmit	Switch 1: 08-Tx	13	01	C-LCP-S11A-C01 12-Strand 62.5/125 um Multi-mode TO LCP-S11A	
0	Plant Control Network Receive	Switch 1: 08-Rx	14	02		
0	Remote I/O Network Transmit	PP1: 03	15	03		
0	Remote I/O Network Receive	PP1: 04	16	04		
0	Plant Monitoring Network Transmit	Switch 2: 08-Tx	17	05		
0	Plant Monitoring Network Receive	Switch 2: 08-Rx	18	06		
0	Spare		19	07		
0	Spare		20	08		
0	Spare		21	09		
0	Spare		22	10		
0	Spare		23	11		
0	Spare		24	12		

NOTES: 1. Panel and Cabling are not in Contract 742-2005. Drawing Issued for Information Only.	B.M. ELEV.			 		ENGINEER'S SEAL ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29 CONSULTANT DRAWING NO. WH-A0520	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION				
				DESIGNED BY	SWT		CHECKED BY	SWT	WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL	CITY FILE NUMBER	
				DRAWN BY	SWT		APPROVED BY	AHL	SHEET 20 OF 88		
				SCALE:	NTS		RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI	CITY DRAWING NUMBER		
 Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.			NO.	REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29	AUTOMATION / I AND C PLANT COMMUNICATION CABLE TERMINATION DIAGRAMS 1-0601H-J-A0520-001-01B