



Rev.	Comments	Jumper or Internal Cable	Conductor #	Cable	Cable Information	
		PP1				
0	Plant Control Network Receive	Switch 1: 07-Rx	01	C-LCP-S11A-C01	12-Strand 62.5/125 um Multi-mode TO CP-J11A	
0	Plant Control Network Transmit	Switch 1: 07-Tx	02			
0	Remote I/O Network Receive	RIO Repeater: 01-Rx	03			
0	Remote I/O Network Transmit	RIO Repeater: 01-Tx	04			
0	Plant Monitoring Network Receive	Switch 2: 07-Rx	05			
0	Plant Monitoring Network Transmit	Switch 2: 07-Tx	06			
0	Spare		07			
0	Spare		08			
0	Spare		09			
0	Spare		10			
0	Spare		11			
0	Spare		12			
0	Plant Control Network Transmit	Switch 1: 08-Tx	13	C-CP-H30A-C02	12-Strand 62.5/125 um Multi-mode TO CP-H30A	
0	Plant Control Network Receive	Switch 1: 08-Rx	14			
0	Remote I/O Network Transmit	RIO Repeater: 02-Tx	15			
0	Remote I/O Network Receive	RIO Repeater: 02-Rx	16			
0	Plant Monitoring Network Transmit	Switch 2: 08-Tx	17			
0	Plant Monitoring Network Receive	Switch 2: 08-Rx	18			
0	Spare		19			
0	Spare		20			
0	Spare		21			
0	Spare		22			
0	Spare		23			
0	Spare		24			

NOTES: 1. Panel and Cabling are not in Contract 742-2005. Drawing Issued for Information Only.	B.M. ELEV.				 		ENGINEER'S SEAL		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION		
	DESIGNED BY		SWT	CHECKED BY		SWT	ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29				WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL
	DRAWN BY		SWT	APPROVED BY		AHL			CONSULTANT DRAWING NO. WH-A0560		AUTOMATION / I AND C PLANT COMMUNICATION CABLE TERMINATION DIAGRAMS
	SCALE:		NTS		RELEASED FOR CONSTRUCTION BY:		R. SOROKOWSKI				CITY DRAWING NUMBER 1-0601H-J-A0560-001-01B
	NO.	REVISIONS	DATE	BY	DATE	2006/03/29			DATE	2006/03/29	

