



Rev.	Comments	Jumper or Internal Cable	Conductor #	Cable	Cable Information
		PP2			
0	Plant Control Network Receive	PP2: 13	01	C-LCP-T11A-C02	12-Strand 62.5/125 um Multi-mode TO CP-H11A
0	Plant Control Network Transmit	PP2: 14	02		
0	Spare		03		
0	Spare		04		
0	Plant Monitoring Network Receive	PP2: 17	05		
0	Plant Monitoring Network Transmit	PP2: 18	06		
0	Spare		07		
0	Spare		08		
0	Spare		09		
0	Spare		10		
0	Spare		11		
0	Spare		12		
0	Plant Control Network Transmit	PP2: 01	13	C-CP-J11A-C01	12-Strand 62.5/125 um Multi-mode TO CP-J11A
0	Plant Control Network Receive	PP2: 02	14		
0	Remote I/O Network Transmit	RIO Repeater: 02-Tx	15		
0	Remote I/O Network Receive	RIO Repeater: 02-Rx	16		
0	Plant Monitoring Network Transmit	PP2: 05	17		
0	Plant Monitoring Network Receive	PP2: 06	18		
0	Spare		19		
0	Spare		20		
0	Spare		21		
0	Spare		22		
0	Spare		23		
0	Spare		24		

<b>NOTES:</b> 1. Panel and Cabling are not in Contract 742-2005. Drawing Issued for Information Only.	B.M. ELEV.			 		<b>ENGINEER'S SEAL</b>  ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29  CONSULTANT DRAWING NO. WH-A0564	<b>THE CITY OF WINNIPEG</b> <b>WATER AND WASTE DEPARTMENT</b> <b>ENGINEERING DIVISION</b>			
				DESIGNED BY	SWT		CHECKED BY	SWT	WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL	CITY FILE NUMBER
				DRAWN BY	SWT		APPROVED BY	AHL		SHEET 64 OF 88
				SCALE: <b>NTS</b>			RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI		AUTOMATION / I AND C PLANT COMMUNICATION CABLE TERMINATION DIAGRAMS	CITY DRAWING NUMBER
				NO.	REVISIONS		DATE	BY		1-0601H-J-A0564-001-01B
			1	742-2005 ADDENDUM 6	06/05/25	SWT				
			0	ISSUED FOR TENDER	06/03/29	SWT				

