




REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
0	C-WTPWSCR02-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPWSCR02	Operator Workstation 02 Network Cable	
0	C-WTPWSCR03-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPWSCR03	Operator Workstation 03 Network Cable	
0	C-WTPWSCR04-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPWSCR04	Operator Workstation 04 Network Cable	
0	C-WTPWSD01 01-C01	4-Pair #24 AWG - Cat 5E		CP-D01A DBPS Communication Panel	WTPWSD01 01	Local Operator Workstation at CP-D01 Network Cable	Not in Contract 742-2005.
0	C-WTPWSF01 01-C01	4-Pair #24 AWG - Cat 5E		LCP-F01A Filters 1-4 Communication Panel	WTPWSF01 01	Local Operator Workstation at LCP-F01 Network Cable	
0	C-WTPWSH10 01-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	WTPWSH10 01	Local Operator Workstation at LCP-H10 Network Cable	
0	C-WTPWSH11 01-C01	4-Pair #24 AWG - Cat 5E		CP-H11A Generator Communication Panel	WTPWSH11 01	Local Operator Workstation at CP-H11 Network Cable	Not in Contract 742-2005.
0	C-WTPWSH32 01-C01	4-Pair #24 AWG - Cat 5E		CP-H32A Backup Server Room Communication Panel	WTPWSH32 01	Local Operator Workstation at CP-H32A Network Cable	
0	C-WTPWSJ11 01-C01	4-Pair #24 AWG - Cat 5E		CP-J11A Sodium Hypochlorite Communication Panel	WTPWSJ11 01	Local Operator Workstation at CP-J11 Network Cable	Not in Contract 742-2005.
0	C-WTPWSO30 01-C01	4-Pair #24 AWG - Cat 5E		CP-O30A Ozone Communication Panel	WTPWSO30 01	Local Operator Workstation at CP-O30 Network Cable	
0	C-WTPWSR21 01-C01	4-Pair #24 AWG - Cat 5E		LCP-R21A Residuals Communication Panel	WTPWSR21 01	Local Operator Workstation at LCP-R21 Network Cable	
0	C-WTPWSS11 01-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	WTPWSS11 01	Local Operator Workstation at LCP-S11 Network Cable	Not in Contract 742-2005.
0	C-WTPWST11 01-C01	4-Pair #24 AWG - Cat 5E		LCP-T11A Clearwell Communication Panel	WTPWST11 01	Local Operator Workstation at LCP-T11 Network Cable	Not in Contract 742-2005.
0	P-CP-D01A	4-C #14 AWG		CP-D01 DBPS Control Panel	CP-D01A DBPS Communication Panel	UPS & non-UPS Panel Power	Not in Contract 742-2005.
0	P-LCP-H10A	4-C #14 AWG		LCP-H10 Electrical Room No. 1 Control Panel	LCP-H10A Electrical Room No. 1 Communication Panel	UPS & non-UPS Panel Power	

NOTES:  <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.		 		ENGINEER'S SEAL		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	
			DESIGNED BY SWT		CHECKED BY SWT			
			DRAWN BY SWT		APPROVED BY AHL		CITY FILE NUMBER	
	1 742-2005 ADDENDUM 6 06/05/25 SWT		SCALE: NTS		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI		SHEET 8 OF 11	
	0 ISSUED FOR TENDER 06/03/29 SWT						CITY DRAWING NUMBER	
NO. REVISIONS		DATE BY		DATE 2006/03/29 DATE 2006/03/29		AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST		
						CONSULTANT DRAWING NO. WH-A0608		
						1-0601H-K-A0608-001-01B		

Thursday, May 25, 2006