




CP-C11A	Polymer Communication Panel				
Comments	Jumper or Internal Cable	Conductor #	Cable	Cable Information	
Primary Polymer PLC	Switch 1	01	RJ-45	C-CP-C11-C01	4-Pair #24 AWG - Cat 5E TO CP-C11
Standby Polymer PLC		02	RJ-45	C-CP-C11-C02	4-Pair #24 AWG - Cat 5E TO CP-C11
Spare		03			
Spare		04			
Spare		05			
Spare		06			
Plant Control Network Receive	PP1: 01	07-Rx			
Plant Control Network Transmit	PP1: 02	07-Tx			
Plant Control Network Receive	PP1: 14	08-Rx			
Plant Control Network Transmit	PP1: 13	08-Tx			
	Switch 2	01	RJ-45	C-WTPWSC11 01-C01	4-Pair #24 AWG - Cat 5E TO WTPWSC11 01
Spare		02			
Spare		03			
Spare		04			
Spare		05			
Spare		06			
Plant Monitoring Network Receive	PP1: 05	07-Rx			
Plant Monitoring Network Transmit	PP1: 06	07-Tx			
Plant Monitoring Network Receive	PP1: 18	08-Rx			
Plant Monitoring Network Transmit	PP1: 17	08-Tx			

NOTES:   <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.			 		ENGINEER'S SEAL		<b>THE CITY OF WINNIPEG</b> <b>WATER AND WASTE DEPARTMENT</b> <b>ENGINEERING DIVISION</b>	
				DESIGNED BY	SWT	CHECKED BY	SWT		
				DRAWN BY	SWT	APPROVED BY	AHL	WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL	
				SCALE:	NTS		RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI	CITY FILE NUMBER SHEET 2 OF 63
	0 ISSUED FOR TENDER 06/03/29 SWT			NO.	REVISIONS	DATE	BY	DATE	CITY DRAWING NUMBER 1-0601H-J-A0502-001-00B

Monday, April 03, 2006