CP-H30A Plant Master PLC Communication Panel	Income of Internal Cold			
Comments	Jumper or Internal Cable	Conducto	or # Cable	Cable Infor
		PP3		
Plant Control Network Receive	PP2: 13	01 01	C-CP-H30A-C03	12-Strand 6
Plant Control Network Transmit	PP2: 14	02 02		
Spare		03 03		
Spare		04 04	<u> </u>	
Spare		05 05		
Spare		06 06		
Spare		07 07		
Spare		08 08		
Spare		09 09		
Spare		10 10		
Spare		11 11		
Spare		12 12		
Plant Control Network Transmit	PP2: 01	13 01	C-CP-O11A-C01	12-Strand 6
Plant Control Network Receive	PP2: 02	14 02		
Spare		15 03		
Spare		16 04		
Spare		17 05		
Spare		18 06		
Spare		19 07		
Spare		20 08		
Spare		21 09		
Spare		22 10		
Spare		23 11		
Spare		24 12		

DTES: B.M. ELEV.			CH2MHILL Frederickson Cooper		ENGINEER'S SEAL ORIGINAL SIGNED BY	THE water engine	
No. 730 Expiry: April 30, 2006.			DESIGNED BY SWT DRAWN BY	CHECKED BY SWT	S.W. TORMEY 2006/03/29	WATER TREA PLANT U	
				SWT	BY AHL] _	MECHANICAL A
	0 ISSUED FOR TENDER	06/03/29 5			RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI	CONSULTANT DRAWING NO.	AUTOMATIO PLANT COMMUN
	NO. REVISIONS	DATE	BY	DATE 2006/03/29	DATE 2006/03/29	WH-A0511	TERMINATIO

Monday, April 03, 2006

formation

62.5/125 um Multi-mode TO CP-O11A

62.5/125 um Multi-mode TO CP-O11A

E CITY OF WINNIPEG or and waste department neering division						
ATMENT PLANT UTILITIES AND ELECTRICAL	CITY FILE NUMBER SHEET OF 63					
TION / I AND C UNICATION CABLE ION DIAGRAMS	CITY DRAWING NUMBER 1-0601H-J-A0511-001-00B					