CP-H30A Plant Master PLC Communication Panel					
Comments	Jumper or Internal Cable		Conductor #	Cable	Cable Info
		RIO Repeater			
	PP1: 03	01-Rx			
	PP1: 04	01-Tx			
	PP1: 16	02-Rx			
	PP1: 15	02-Tx			
		Coax	01	C-CP-H30-C03	1-Coaxial R
		Switch 1			
Primary Plant Master PLC		01	RJ-45	C-CP-H30-C01	4-Pair #24 /
Standby Plant Master PLC		02	RJ-45	C-CP-H30-C02	4-Pair #24 /
Spare		03			
Spare		04			
Spare		05			
Spare		06			
Plant Control Network Receive	PP1: 01	07-Rx			
Plant Control Network Transmit	PP1: 02	07-Tx			
Plant Control Network Receive	PP1: 14	08-Rx			
Plant Control Network Transmit	PP1: 13	08-Tx			
4					

NOTES:		B.M. ELEV.			CH2M HILL Frederickson Cooper		EarthTech		ENGINEER'S SEAL	THE CITY OF WINNIPEG water and waste department	
					ARCHITECTS				ORIGINAL SIGNED BY	ENGINEERING DIVISION	
Certificate of Authorization Earth Tech Canada Inc.					DESIGNED BY	SWT	CHECKED BY	SWT	S.W. TORMEY 2006/03/29	WATER TREATMENT PLANT	CITY FILE NUMBER
				—	DRAWN BY SWT	APPROVED BY	AHL	2000/03/25	PLANT UTILITIES SHEET MECHANICAL AND ELECTRICAL	SHEET OF 63	
							RELEASED FOR CONSTRUCTION BY:			AUTOMATION / I AND C	CITY DRAWING NUMBER
No. 730 Expiry: April 30, 2006.	0	ISSUED FOR TENDER	06/03/29	SWT		NTS	R. SOROKO		CONSULTANT DRAWING NO.	PLANT COMMUNICATION CABLE	
но. 750 — Едриј. При 50, 2000.	NO.	REVISIONS	DATE	BY	DATE	2006/03/29	DATE 20	006/03/29	WH-A0512	TERMINATION DIAGRAMS	1-0601H-J-A0512-001-00B

Monday, April 03, 2006

nformation

I RG-6 TO CP-H30

24 AWG - Cat 5E TO CP-H30 24 AWG - Cat 5E TO CP-H30