Comments	Jumper or Internal Cable		Conductor #	Cable	Cable Inform
		PP1			
Plant Control Network Receive	Switch 1: 07-Rx	01	01	C-CP-J11A-C01	12-Strand 6
Plant Control Network Transmit	Switch 1: 07-Tx	02	02		
Remote I/O Network Receive	PP1: 15	03	03		
Remote I/O Network Transmit	PP1: 16	04	04		
Plant Monitoring Network Receive	Switch 2: 07-Rx	05	05		
Plant Monitoring Network Transmit	Switch 2: 07-Tx	06	06		
Spare		07	07		
Spare		08	08		
Spare		09	09		
Spare		10	10		
Spare		11	11		
Spare		12	12		
Plant Control Network Transmit	Switch 1: 08-Tx	13	01	C-LCP-S11A-C01	12-Strand 6
Plant Control Network Receive	Switch 1: 08-Rx	14	02		
Remote I/O Network Transmit	PP1: 03	15	03		
Remote I/O Network Receive	PP1: 04	16	04		
Plant Monitoring Network Transmit	Switch 2: 08-Tx	17	05		
Plant Monitoring Network Receive	Switch 2: 08-Rx	18	06		
Spare		19	07		
Spare		20	08		
Spare		21	09		
Spare		22	10		
Spare		23	11		
Spare		24	12		

NOTES: 1. Panel and Cabling are not in Contract 742-2005. Drawing Issued for Information Only.	B.M ELE				Frederic	Ch2M HILL	Eart A Tyco Intern	hTech ational Ltd. Company	ENGINEER'S SEAL	THE water
					(0 - 103 - 1 4 C 4	St. Winning, Westlobe			ORIGINAL SIGNED BY	ENGINI
					DESIGNED BY	SWT	CHECKED BY	SWT	S.W. TORMEY 2006/03/29	WATER TREA
Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.				DRAWN BY	SWT	APPROVED BY	AHL		PLANT U MECHANICAL A	
	ISSUED FOR TENDER	06/03/29		SCALE:		RELEASED F CONSTRUCT R. SORC		CONSULTANT DRAWING NO.	AUTOMATI PLANT COMMUN	
	NO	REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29	WH-A0518	TERMINATIC

Monday, April 03, 2006

formation

62.5/125 um Multi-mode TO LCP-T11A

62.5/125 um Multi-mode TO LCP-S11A

E CITY OF WINNIPEG ER AND WASTE DEPARTMENT NEERING DIVISION							
ATMENT PLANT UTILITIES	CITY FILE NUMBER						
AND ELECTRICAL	18 63						
TION / I AND C	CITY DRAWING NUMBER						
UNICATION CABLE							
ION DIAGRAMS	1-0601H-J-A0518-001-00B						