Comments	Jumper or Internal Cable		Conductor #	Cable	Cable Infor
		PP1			
Plant Control Network Receive	Switch 1: 07-Rx	01	01	C-LCP-H10A-C01	12-Strand 6
Plant Control Network Transmit	Switch 1: 07-Tx	02	02		
Remote I/O Network Receive	RIO Repeater: 01-Rx	03	03		
Remote I/O Network Transmit	RIO Repeater: 01-Tx	04	04		
Plant Monitoring Network Receive	Switch 2: 07-Rx	05	05		
Plant Monitoring Network Transmit	Switch 2: 07-Tx	06	06		
Spare		07	07		
Spare		08	08		
Spare		09	09		
Spare		10	10		
Spare		11	11		
Spare		12	12		
Plant Control Network Transmit	Switch 1: 08-Tx	13	01	C-LCP-L11A-C01	12-Strand 62
Plant Control Network Receive	Switch 1: 08-Rx	14	02		
Spare		15	03		
Spare		16	04		
Spare		17	05		
Spare		18	06		
Spare		19	07		
Spare		20	08		
Spare		21	09		
Spare		22	10		
Spare		23	11		
Spare		24	12		

NOTES:	B.M. ELEV.			CH2MHILL Frederickson Cooper		ENGINEER'S SEAL ORIGINAL SIGNED BY	THE water engine
			DESIGNED BY SWT DRAWN BY	CHECKED BY SWT	S.W. TORMEY 2006/03/29	WATER TREAT PLANT U	
				SWT	BY AHL	Ν	MECHANICAL A
Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.	0 ISSUED FOR TENDER	06/03/29		NTS	RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI	CONSULTANT DRAWING NO.	AUTOMATI PLANT COMMUN
Тю. 750 — Ехриу. Трін 56, 2000.	NO. REVISIONS	DATE	BY	DATE 2006/03/29	DATE 2006/03/29	WH-A0533	TERMINATIO

Monday, April 03, 2006

formation

62.5/125 um Multi-mode TO CP-H31A

62.5/125 um Multi-mode TO LCP-L11A

E CITY OF WINNIPEG or and waste department neering division						
ATMENT PLANT `UTILITIES AND ELECTRICAL	CITY FILE NUMBER SHEET 33 OF 63					
TION / I AND C UNICATION CABLE ION DIAGRAMS	CITY DRAWING NUMBER 1-0601H-J-A0533-001-00B					