




LCP-P31 DAF Basin 1 VFD Control Panel							
Comments	Jumper or Internal Cable	Conductor #	Cable	Cable Information			
				Switch 1			
Floculator FLC-P101A	RJ-45 To Floculator FLC-P101A	01					
Floculator FLC-P102A	RJ-45 To Floculator FLC-P102A	02					
Floculator FLC-P103A	RJ-45 To Floculator FLC-P103A	03					
Floculator FLC-P104A	RJ-45 To Floculator FLC-P104A	04					
Floculator FLC-P105A	RJ-45 To Floculator FLC-P105A	05					
Floculator FLC-P106A	RJ-45 To Floculator FLC-P106A	06					
Skimmer DF-P100A	RJ-45 To Skimmer DF-P100A	07					
		08	RJ-45	C-LCP-P31-C01	4-Pair #24 AWG - Cat 5E TO CP-P31		

NOTES: 1. Panel Supplied by the City.	B.M. ELEV.			 		ENGINEER'S SEAL		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION				
				DESIGNED BY	SWT	CHECKED BY	SWT			WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL		
				DRAWN BY	SWT	APPROVED BY	AHL	CITY FILE NUMBER				
				SCALE: NTS		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI		SHEET 48 OF 63				
	 Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.			0	ISSUED FOR TENDER	06/03/29	SWT	CITY DRAWING NUMBER 1-0601H-J-A0548-001-00B				
			NO.	REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29	AUTOMATION / I AND C PLANT COMMUNICATION CABLE TERMINATION DIAGRAMS	
							CONSULTANT DRAWING NO. WH-A0548					

Monday, April 03, 2006