



REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
0	C-CP-P31A-C01	12-Strand 62.5/125 um Multi-mode		CP-H32A Backup Server Room Communication Panel	CP-P31A DAF Communication Panel	Plant Communication	
0	C-CP-P31-C01	4-Pair #24 AWG - Cat 5E		CP-P31A DAF Communication Panel	CP-P31 DAF Basins 1-4 Control Panel	DAF Control	
0	C-CP-P32-C01	4-Pair #24 AWG - Cat 5E		CP-P31A DAF Communication Panel	CP-P32 DAF Basins 5-8 Control Panel	DAF Control	
0	C-JT-H951A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H951A	SWGR 1A Power Meter Comm. Cable	
0	C-JT-H951B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H951B	SWGR 1B Power Meter Comm. Cable	
0	C-JT-H952A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H952A	MCC 1A Power Meter Comm. Cable	
0	C-JT-H952B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H952B	MCC 1B Power Meter Comm. Cable	
0	C-JT-H953A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H953A	MCC 2A Power Meter Comm. Cable	
0	C-JT-H953B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H953B	MCC 2B Power Meter Comm. Cable	
0	C-JT-H954A-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H954A	MCC 3A Power Meter Comm. Cable	
0	C-JT-H954B-C01	4-Pair #24 AWG - Cat 5E		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H954B	MCC 3B Power Meter Comm. Cable	
0	C-JT-H961A-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JT-H961A	SWGR 2A Power Meter Comm. Cable	Not in Contract 742-2005.
0	C-JT-H961B-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JT-H961B	SWGR 2B Power Meter Comm. Cable	Not in Contract 742-2005.
0	C-JT-H962A-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JT-H962A	MCC 4A Power Meter Comm. Cable	Not in Contract 742-2005.
0	C-JT-H962B-C01	4-Pair #24 AWG - Cat 5E		LCP-S11A Bulk Chemical Communication Panel	JT-H962B	MCC 4B Power Meter Comm. Cable	Not in Contract 742-2005.

NOTES:	B.M. ELEV.		 		ENGINEER'S SEAL	<b>THE CITY OF WINNIPEG</b> <b>WATER AND WASTE DEPARTMENT</b> <b>ENGINEERING DIVISION</b>						
			DESIGNED BY	CHECKED BY				ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29	WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL		CITY FILE NUMBER	
			DRAWN BY	APPROVED BY					CONSULTANT DRAWING NO. WH-A0603	SHEET 3 OF 9		
			SCALE:	RELEASED FOR CONSTRUCTION BY:						AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST		CITY DRAWING NUMBER
			0 ISSUED FOR TENDER	R. SOROKOWSKI						1-0601H-K-A0603-001-00B		
		NO. REVISIONS	DATE	BY	DATE	DATE						



Monday, April 03, 2006