


NOTES:
 1. ALL FLOW METERS TO BE INSTALLED WITH MINIMUM STRAIGHT UPSTREAM AND DOWNSTREAM PIPE RUNS ACCORDING TO MANUFACTURER'S REQUIREMENTS.
 2. FOR ADDITIONAL INFORMATION ON PIPE EMBEDS, REFER TO SERIES WP-M9000 DRAWINGS.

1 THIRD FLOOR PLAN
 WP-M0130 1:150

6 PLAN - TYP. LAYOUT - MUD VALVE OPERATORS
 WP-M0131 1:25



APCA
 Certificate of Authorization
 Earth Tech Canada Inc.
 No. 730 Expiry: April 30, 2006

B.M. ELEV.			
DESIGNED BY	K.A.S.	CHECKED BY	SMB
DRAWN BY	P.L./LPT/LC	APPROVED BY	AHL
SCALE:	AS SHOWN	RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI
NO. REVISIONS		DATE	2005/09/30
		DATE	2006/03/29

CH2M HILL
 Frederickson Cooper ARCHITECTS
 EarthTech
 A Tyco International Ltd. Company
 ENGINEER'S SEAL
 ORIGINAL SIGNED BY
 S.M. BREESE
 2006/03/29
 CONSULTANT DRAWING NO.
 WP-M0130

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT
 ENGINEERING DIVISION
 WATER TREATMENT PLANT
 FLOCCULATION AND DAF
 MECHANICAL AND ELECTRICAL
 PROCESS MECHANICAL
 THIRD FLOOR PLAN
 CITY FILE NUMBER
 SHEET OF
 CITY DRAWING NUMBER
 1-0601P-A-M0130-001-000