



1 HEATING SCHEMATIC - STACKED BOILER S760-GH & S765-GH  
LM4.03 SCALE N.T.S.

**GENERAL NOTES**

1. PUMPS ARE CONTROLLED FROM BOILER CONTROL PANEL.
2. REFER TO SPEC. SECTION 15940 FOR ADDITIONAL CONTROL REQUIREMENTS.



B.M. ELEV.		 A Tyco International Ltd. Company		ENGINEER'S SEAL		 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	
				DESIGNED BY: AB			
		DRAWN BY: DL		APPROVED BY: JEH		ORIGINAL SIGNED BY: A. BURACHYNSKY	
		HOR. SCALE: AS NOTED		RELEASED FOR CONSTRUCTION BY: J. VEILLEUX		2006/04/26	
		DATE: 2006/01/02		DATE: 2006/04/26		CONSULTANT DRAWING NO. LM4.03	
NO. REVISIONS		DATE		BY		CITY FILE NUMBER	
						SHEET OF	
						CITY DRAWING NUMBER	