



- NOTES:**
1. INSTALL NEW PNEUMATIC OPERATOR ON EXISTING VALVE.
  2. EXISTING VALVE S112-HV1-V302 RENAMED AS S114-FCV.



BIOREACTOR 2 MIXER 1	BIOREACTOR 2 MIXER 2	BIOREACTOR 2 MIXER 3	BIOREACTOR 2 MIXER 4
EQUIP. NO.: S-765-MXR SPEC: 11395 TYPE: SUBMERSIBLE PROPELLER DRIVE: FIXED SPEED POWER: 3.75 kW	EQUIP. NO.: S-766-MXR SPEC: 11395 TYPE: SUBMERSIBLE PROPELLER DRIVE: FIXED SPEED POWER: 3.75 kW	EQUIP. NO.: S-767-MXR SPEC: 11395 TYPE: SUBMERSIBLE PROPELLER DRIVE: FIXED SPEED POWER: 3.75 kW	EQUIP. NO.: S-768-MXR SPEC: 11395 TYPE: SUBMERSIBLE PROPELLER DRIVE: FIXED SPEED POWER: 3.75 kW

<p>A Tyco International Ltd. Company</p>		<p>ENGINEER'S SEAL</p> <p>ORIGINAL SIGNED BY</p> <p>S.W. TORMEY</p> <p>2006/04/26</p>		<p>THE CITY OF WINNIPEG</p> <p>WATER AND WASTE DEPARTMENT</p> <p>ENGINEERING DIVISION</p>		
DESIGNED BY: CGL/EVS	CHECKED BY: KM/ST	<p>WEWPC</p> <p>BIOLOGICAL NUTRIENT REMOVAL UPGRADE</p> <p>CONTRACT 3</p>		CITY FILE NUMBER		
DRAWN BY: LAE/PPL	APPROVED BY: JEH	<p>CONSULTANT DRAWING NO.</p> <p>LI2.03</p>		SHEET OF		
<p>HOR. SCALE: NONE</p> <p>VERTICAL SCALE:</p>		<p>RELEASED FOR CONSTRUCTION BY:</p> <p>J. VEILLEUX</p>		CITY DRAWING NUMBER		
NO. REVISIONS	DATE	BY	DATE	2005/07/06	DATE	2006/04/26