



PRIMARY SLUDGE PUMP 1
 EQUIP. NO.: P-250-SLP
 SPEC: 11320
 TYPE: RECESSED IMPELLER CENTRIFUGAL
 CAPACITY: 10-20 L/s
 HEAD: 2.2-4.3 m
 POWER: 3.75 kw

PRIMARY SLUDGE PUMP 2
 EQUIP. NO.: P-260-SLP
 SPEC: 11320
 TYPE: RECESSED IMPELLER CENTRIFUGAL
 CAPACITY: 10-20 L/s
 HEAD: 2.2-4.3 m
 POWER: 3.75 kw



B.M. ELEV.			
DESIGNED BY	YL/EVS	CHECKED BY	KM/ST
DRAWN BY	PY/PPL	APPROVED BY	JEH
HOR. SCALE:	NONE	RELEASED FOR CONSTRUCTION BY:	J. VEILLEUX
VERTICAL SCALE:		DATE	2005/07/06
NO. REVISIONS		DATE	2006/04/26

EarthTech
 A Tyco International Ltd. Company

ENGINEER'S SEAL
 ORIGINAL SIGNED BY
 S.W. TORMEY
 2006/04/26
 CONSULTANT DRAWING NO.
 LI1.01

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT
 ENGINEERING DIVISION

WEWPCC
 BIOLOGICAL NUTRIENT REMOVAL UPGRADE
 CONTRACT 3

PROCESS
 AREA P - PRIMARY CLARIFIERS
 PRIMARY SLUDGE PUMPING - P&ID

CITY FILE NUMBER
 SHEET OF
 CITY DRAWING NUMBER