



**GENERAL NOTES**

1. ALL NEW I/O ASSOCIATED WITH THE HEADWORKS, PRIMARY CLARIFIERS, FERMENTERS, DAF THICKENERS, AND CHEMICAL SYSTEMS ARE TO BE WIRED BACK TO PCU A.
2. ALL NEW I/O ASSOCIATED WITH SECONDARY CLARIFIERS AND BIOWEASERS ARE TO BE WIRED BACK TO PCU B.
3. THIS DRAWING IS INTENDED TO BE FOR INFORMATION PURPOSES ONLY. SHOWING THE LOCATION OF THE EXISTING CONTROL SYSTEM.



NO.	REVISIONS	DATE	BY
00	ISSUED FOR TENDER	06/04/26	CD

<p>A Tyco International Ltd. Company</p>		DESIGNED BY	CD	CHECKED BY	EVS
		DRAWN BY	PPL	APPROVED BY	JEH
HOR. SCALE: NONE		RELEASED FOR CONSTRUCTION BY:		J. VEILLEUX	
VERTICAL SCALE:		DATE		2006/01/06	
		DATE		2006/04/26	

ENGINEER'S SEAL
ORIGINAL SIGNED BY
S.W. TORMEY
2006/04/26
CONSULTANT DRAWING NO.
LI5.01

<p><b>THE CITY OF WINNIPEG</b> WATER AND WASTE DEPARTMENT ENGINEERING DIVISION</p>		CITY FILE NUMBER
<p><b>WEWPCC</b> BIOLOGICAL NUTRIENT REMOVAL UPGRADE CONTRACT 3</p>		SHEET OF
<p>INSTRUMENTATION AREA L - GENERAL AND SITWORKS SITE PLAN</p>		CITY DRAWING NUMBER