



1 HEATING SCHEMATIC – STACKED BOILER S760-GH & S765-GH  
 LM4.03 SCALE N.T.S.

**GENERAL NOTES**

- PUMPS ARE CONTROLLED FROM BOILER CONTROL PANEL.
- REFER TO SPEC. SECTION 15900 FOR ADDITIONAL CONTROL REQUIREMENTS.



|                      |                   |   |        |
|----------------------|-------------------|---|--------|
| DESIGNED BY AB       |                   | CHECKED BY PVL                            |        |
| DRAWN BY DL          |                   | APPROVED BY JEH                           |        |
| HOR. SCALE: AS NOTED |                   | RELEASED FOR CONSTRUCTION BY: J. VEILLEUX |        |
| VERTICAL SCALE:      |                   | DATE 2006/01/02                           |        |
| NO. 00               | ISSUED FOR TENDER | DATE 06/04/26                             | BY LJW |

ENGINEER'S SEAL  
 ORIGINAL SIGNED BY  
 A. BURACHYNSKY  
 2006/04/26  
 CONSULTANT DRAWING NO.  
 LM4.03

**THE CITY OF WINNIPEG**  
 WATER AND WASTE DEPARTMENT  
 ENGINEERING DIVISION

**WEWPCC**  
 BIOLOGICAL NUTRIENT REMOVAL UPGRADE  
 CONTRACT 3

MECHANICAL  
 AREA L – GENERAL AND SITEWORKS  
 HEATING AND VENTILATION SCHEMATICS

CITY FILE NUMBER  
 SHEET OF  
 CITY DRAWING NUMBER