



LIGHTING & SYSTEMS PLAN
SCALE: 1:25

DRAWING NOTES

- ① COORDINATE LUMINAIRE CONNECTIONS WITH MECHANICAL PIPING AND DUCTWORK. WHERE REQUIRED SUSPEND LUMINAIRES BELOW SUCH EQUIPMENT.
- ② CONNECT NEW EMERGENCY LIGHTS TO EXISTING EMERGENCY LIGHTING CIRCUIT SEAA-4 AT EXISTING LUMINAIRE IN CORRIDOR AS SHOWN ON DRAWING.

GENERAL NOTES

1. COORDINATE WITH OTHER TRADES TO PREVENT CONFLICTS.
2. USE PVC JACKETED HITECK CABLE FOR ALL POWER WIRING.
3. WIRING FOR LIGHTING, RECEPTACLES AND COMMUNICATIONS TO IN RIGID ALUMINUM CONDUIT.
4. ALL CONDUIT TO BE 21mmØ MINIMUM UNLESS OTHERWISE NOTED.



B.M. ELEV.			
00	ISSUED FOR TENDER	06/04/26	ERC
NO.	REVISIONS	DATE	BY



DESIGNED BY	GSN	CHECKED BY	PS
DRAWN BY	ERC	APPROVED BY	JEH
HOR. SCALE:	NTS	RELEASED FOR CONSTRUCTION BY:	J. VEILLEUX
VERTICAL SCALE:		DATE	2005/11/22
		DATE	2006/04/26

ENGINEER'S SEAL
ORIGINAL SIGNED BY
P. STRYK
2006/04/26
CONSULTANT DRAWING NO.
SE2.01

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

WEWPCC
BIOLOGICAL NUTRIENT REMOVAL UPGRADE
CONTRACT 3

ELECTRICAL
AREA S - BIOREACTORS
ELECTRICAL ROOM LIGHTING AND SYSTEMS PLAN

CITY FILE NUMBER
SHEET OF
CITY DRAWING NUMBER