



MAIN FLOOR – LIGHTING & SYSTEMS PLAN
SCALE: 1:100

DRAWING NOTES

- ① COORDINATE LUMINAIRE CONNECTIONS WITH MECHANICAL PIPING AND DUCTWORK. WHERE REQUIRED SUSPEND LUMINAIRES BELOW SUCH EQUIPMENT.
- ② CONDUCTOR TO PANEL SAA IN SECONDARY CLARIFIER ELECTRICAL ROOM.

GENERAL NOTES

- 1. COORDINATE WITH OTHER TRADES TO PREVENT CONFLICTS.
- 2. USE PVC JACKETED HITECK CABLE FOR ALL POWER WIRING.
- 3. WIRING FOR LIGHTING, RECEPTACLES AND COMMUNICATIONS TO IN RIGID ALUMINUM CONDUIT.
- 4. ALL CONDUIT TO BE 21mm# MINIMUM UNLESS OTHERWISE NOTED.



B.M. ELEV.			
00 ISSUED FOR TENDER	06/04/26	ERC	
NO. REVISIONS	DATE	BY	

 A Tyco International Ltd. Company		DESIGNED BY	GSN	CHECKED BY	PS
		DRAWN BY	ERC	APPROVED BY	JEH
HOR. SCALE:		AS NOTED			
VERTICAL SCALE:		RELEASED FOR CONSTRUCTION BY:			
		J. VEILLEUX			
	DATE	2005/12/19	DATE	2006/04/26	

ENGINEER'S SEAL
ORIGINAL SIGNED BY
P. STRYK
2006/04/26
CONSULTANT DRAWING NO.
SE3.01

 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	WENPCC BIOLOGICAL NUTRIENT REMOVAL UPGRADE CONTRACT 3	CITY FILE NUMBER
	ELECTRICAL AREA S – SECONDARY CLARIFIER 3 MAIN FLOOR LIGHTING AND SYSTEMS PLAN	SHEET OF
		CITY DRAWING NUMBER