


ROOF FRAMING PLAN – BIOREACTOR 2
SCALE : 1:100

- NOTES:**
- EXISTING CONCRETE SURFACE TO BE INTENTIONALLY ROUGHENED TO A FULL AMPLITUDE OF 5mm & TO BE CLEAN, SOUND & FREE OF LAINTANCE. EXISTING CONC. TO BE IN A S.S.D. CONDITION FOR 24 HOURS PRIOR TO CASTING OF CONCRETE INFILL WALLS/BEAMS (SEE SECTION 1 SHEET SS3.03). TYPICAL AT NEW & EXISTING INTERSECTION POINTS FOR: CB-1, CB-2, CB-3, CC-1, SL-1 & CW-6
 - SHORE EXISTING PRECAST DOUBLE TEE'S AS REQUIRED TO SUIT NEW CONSTRUCTION.



B.M. ELEV.		EarthTech A Tyco International Ltd. Company		ENGINEER'S SEAL	
DESIGNED BY	AA/JB	CHECKED BY	AA/JB	ORIGINAL SIGNED BY	J. BETKE
DRAWN BY	WDB	APPROVED BY	JEH	DATE	2006/04/26
HOR. SCALE:	AS NOTED	RELEASED FOR CONSTRUCTION BY:	J. VEILLEUX	CONSULTANT DRAWING NO.	SS2.04
VERTICAL SCALE:		DATE	2005/11/15		
NO.	REVISIONS	DATE	BY	DATE	2006/04/26
00	ISSUED FOR TENDER	06/04/26	KK		

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

WEWPC
BIOLOGICAL NUTRIENT REMOVAL UPGRADE
CONTRACT 3

STRUCTURAL
AREA S – BIOREACTOR 2
ROOF FRAMING PLAN & SCHEDULES

CITY FILE NUMBER
SHEET OF
CITY DRAWING NUMBER