

BID OPPORTUNITY NO. 242-2006, ADDENDUM NO. 1

2006 WATERMAIN RENEWALS - CONTRACT NO. 4

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: April 19, 2006 BY: Doug Berg

TELEPHONE NO. (204) 986-4452

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

PART A - BID SUBMISSION

Replace: BID OPPORTUNITY NO. 242-2006, Bid Submission with BID OPPORTUNITY NO. 242-2006, Addendum NO. 1-

Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B(R1):

Revise: Item No. A.16 to have Approx. Quantity of 30.0

Add: Item No. A.20 – Regrading of Interlocking Paving Stones on a Lean Concrete Base

Add: Item No. A.21 – Cement Stabilized Backfill Material

Revise: Item No. B.14 to have Approx. Quantity of 50.0

Add: Item No. B.18 – Regrading of Interlocking Paving Stones on a Lean Concrete Base

Add: Item No. B.19 – Cement Stabilized Backfill Material

Page numbering on some forms may be changed as a result.

PART D - SUPPLEMENTAL CONDITIONS

Revise: D15.1 to read: The Contractor shall achieve Substantial Performance within seventy-five (75)

consecutive Working Days of the Commencement of the Work as specified in D12.

Revise: D16.1 to read: The Contractor shall achieve Total Performance within eighty-five (85) consecutive

Working Days of the Commencement of the Work as specified in D12.

PART E - SPECIFICATIONS

Revise: E6.1.1 (b) to read: Asphalt and concrete pavements shall be capped with a 100 millimetre thick layer of

"Concrete for Temporary Restoration of Utility Pavement Cuts" as specified in CW 3310.

Add:

E11. REGRADING OF INTERLOCKING PAVING STONES ON A LEAN CONCRETE BASE

- E12.1 This Specification covers the removal of existing interlocking paving stones, preparation of the sub-grade, supply and installation of lean concrete base, and the supply and installation of interlocking paving stones.
- E12.2 Materials are to be in accordance with CW 3335.
- E12.3 Construction methods:
 - (a) Remove and clean existing paving stones from areas disturbed by construction of installation of the new watermain.
 - (b) Prepare the crushed limestone sub-base, lean concrete base and sand bedding as detailed in SD-240B and in accordance with Clause 9.2 of CW 3335.
 - (c) Re-install existing paving stones to match existing elevations and patterns and in accordance with Clause 9.3 of CW 3335.
 - (d) Supply and replacement of damaged paving stones shall be incidental to the cost of regarding the existing paving stones. Replacement paving stones shall be of similar colour and dimensions as the existing paving stones, and shall tie into adjoining interlocking paving stones without cutting of replaced interlocking paving stones.
- E12.4 Method of measurement and basis of payment:
 - (a) Regrading of interlocking paving stones will be measured on a surface area basis. The surface area will be the number of square metres constructed in accordance with this Specification, measured and accepted by the Contract Administrator and paid for at the Contract Unit price for "Regarding of Interlocking Paving Stones on a Lean Concrete Base". The Contract Unit Price for this work will be payment in full for performing all operations herein described and for all other items incidental to the work included in this specification.

Add:

E12. CHANGE IN BACKFILL MATERIAL

- E12.1 Where directed by the Contract Administrator, the Contractor will be required to change the proposed class of backfill for the trenchless installation to Class 1.
- E12.2 Change in backfill material will be measured and paid in accordance with Clause 4.8 of CW 2030 and will include the disposal of excavated material.