



283-2006 ADDENDUM 1

SUPPLY AND DELIVERY OF WATER AND SEWER PIPE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: May 15, 2006
BY: Ken M. Stelmack, C.P.P., C.P.M., C.I.M.
TELEPHONE NO. (204) 986-2293

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050506

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

- Revise: E2.2 to read: Item No's. 1 – 4 water pipe shall be polyvinyl chloride (PVC) water pipe approved for underground use in accordance with the most recent revision of The City of Winnipeg Standard No. AT- 4.1.1.10.
- Revise E2.2.1 to read: Only polyvinyl chloride (PVC) water pipe manufactured to AWWA C900-97, Sec. 4.3.2.2.A shall be supplied.
- Add E2.2.2 to read Only one approved manufacturer's product shall be supplied for each product size:
- (i) Item No. 1 – 150mm x 3m
 - (ii) Item No. 2 – 200mm x 3m
 - (iii) Item No. 3 – 250mm x 3m
 - (iv) Item No. 4 – 300mm x 3m