


4160V CABLES (8kV RATED)
 FROM SECONDARY ELECTRICAL ROOM
 IN THE BLOWER AND CONTROL BUILDING
 TO CENTRATE NITROGEN REMOVAL FACILITY
 PRIMARY TRANSFORMERS
 REFER TO THE OVERALL ELECTRICAL SITE PLAN

A DUCT BANK SECTION
 E2.02 SCALE 1:10



SECONDARY ELECTRICAL ROOM - POWER PLAN
 SCALE: 1:50



B.M. ELEV.	EarthTech A Tyco International Ltd. Company		ENGINEER'S SEAL	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	
	DESIGNED BY PS	CHECKED BY GSN	ORIGINAL SIGNED BY P. STRYK	NEWPCC CENTRATE NUTRIENT TREATMENT NITROGEN REMOVAL FACILITY	
	DRAWN BY CPG	APPROVED BY JEH	2005/05/15	CITY FILE NUMBER	
	SCALE:		CONSULTANT DRAWING NO. E2.02	SHEET OF	
01 291-2006 ADDENDUM 3 06/07/12 CPG	RELEASED FOR CONSTRUCTION BY: K. MARTENS		ELECTRICAL SECONDARY ELECTRICAL ROOM PLAN AND DETAILS		CITY DRAWING NUMBER
00 ISSUED FOR TENDER 06/05/15 CPG	DATE 2006/02/23	DATE 2006/05/23			
NO. REVISIONS	DATE	BY			