



NOTES:

1. CONCRETE COLUMNS AND PEDESTALS OMITTED FOR CLARITY
2. ALL METAL PARTS BENEATH SBR COVERS USED FOR PIPE SUPPORT INCLUDING ANCHORS, RODS AND CLAMPS TO BE SS316. SUBMERGED METAL PARTS IN EQUALIZATION TANK USED FOR PIPE SUPPORT INCLUDING ANCHORS, RODS AND CLAMPS TO BE SS316.
3. DECANTERS SUPPLIED UNDER SEPARATE CONTRACT. INSTALL DECANTERS AS PART OF THIS CONTRACT. COORDINATE EXACT DIMENSIONS WITH DECANTER SUPPLIER.
4. PROVIDE SS316 300# AIR AND 100# AIR BELOW COVER.
5. PROVIDE INTERMEDIATE SUPPORT AS REQUIRED FOR GUIDE RAIL AND PIPE.

 Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007	
---	--

NO.	REVISIONS	DATE	BY
01	291-2006 ADDENDUM 3	06/07/12	LAE
00	ISSUED FOR TENDER	06/05/15	GLG

 A Tyco International Ltd. Company	
DESIGNED BY: YL	CHECKED BY: SB
DRAWN BY: SRP	APPROVED BY: JEH
SCALE: AS NOTED	RELEASED FOR CONSTRUCTION BY: K. MARTENS
DATE: 2006/01/16	DATE: 2006/05/15

ENGINEER'S SEAL
ORIGINAL SIGNED BY: J.E. HUTCHISON
DATE: 2006/05/15
CONSULTANT DRAWING NO. P14.02

 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	
NEWPCC CENTRATE NUTRIENT TREATMENT NITROGEN REMOVAL FACILITY	
PROCESS PROCESS TANK SECTIONS SHEET 2	CITY FILE NUMBER SHEET OF CITY DRAWING NUMBER