



EQUIP. NO.: C510-EF
 TYPE: CENTRIFUGAL FAN
 CAPACITY: 31,000 m³/hr
 HEAD: 0.65 kPa
 POWER: 11.1 kW

APECA
 Certificate of Authorization
 Earth Tech Canada Inc.
 No. 730 Expiry: April 30, 2007

B.M. ELEV.			
DESIGNED BY	EM/CD	CHECKED BY	SB/PS
DRAWN BY	SRP	APPROVED BY	JEH
SCALE:	NONE	RELEASED FOR CONSTRUCTION BY:	K. MARTENS
NO. REVISIONS	DATE	BY	DATE
01	291-2006 ADDENDUM 3	06/07/12	LAE
00	ISSUED FOR TENDER	06/05/15	SRP
		DATE	2006/01/16
		DATE	2006/05/15

EarthTech
 A Tyco International Ltd. Company

ENGINEER'S SEAL
 ORIGINAL SIGNED BY
 Q. MENG
 2006/05/15

CONSULTANT DRAWING NO.
 P9.01

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT
 ENGINEERING DIVISION

NEWPC CENTRATE NUTRIENT TREATMENT
 NITROGEN REMOVAL FACILITY

PROCESS
 EXHAUST FAN SYSTEM
 PROCESS & INSTRUMENTATION DIAGRAM

CITY FILE NUMBER
 SHEET OF
 CITY DRAWING NUMBER