



NOTES:

- ALL METAL PARTS BENEATH SBR COVERS USED FOR PIPE SUPPORT INCLUDING ANCHORS, RODS AND CLAMPS TO BE SS316. SUBMERGED METAL PARTS IN EQUALIZATION TANK USED FOR PIPE SUPPORT INCLUDING ANCHORS, RODS AND CLAMPS TO BE SS316.
- COORDINATE EXACT OPENING DIMENSIONS WITH GATE SUPPLIER. ACTUATOR TO BE FIXED TO GATE FRAME.

<p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007</p>	B.M. ELEV.	<p>A Tyco International Ltd. Company</p>	ENGINEER'S SEAL	<p>THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION</p>							
			DESIGNED BY: YL		CHECKED BY: SB	ORIGINAL SIGNED BY: J.E. HUTCHISON					
			DRAWN BY: SRP		APPROVED BY: JEH	2006/05/15					
			SCALE: AS NOTED		RELEASED FOR CONSTRUCTION BY: K. MARTENS	CONSULTANT DRAWING NO. P14.03					
	NO. REVISIONS	DATE	DATE	DATE	2006/01/16	DATE	2006/05/15	PROCESS SHEET 3	CITY FILE NUMBER	SHEET OF	CITY DRAWING NUMBER
								NEWPCC CENTRATE NUTRIENT TREATMENT NITROGEN REMOVAL FACILITY			1-0101C-A-P0003-003-02D