



NOTE 4. C720 LT 2

NOTE 4. C720 LT 1

EMERGENCY EYEWASH/SHOWER REFER TO MECHANICAL DRAWINGS FOR DETAILS

C700 FS

NOTE 4. LEAK C720 LS

NOTE 3. METHANOL TRUCK UNLOADING PANEL

C710 FCV

C740 FCV

C750 LT 2 NOTE 4.

C750 LT 1 NOTE 4.

LEAK C750 LS NOTE 4.

1 METHANOL DOSING TANKS INSTRUMENT PLAN
SCALE 1:50

- NOTES:
- REFER TO METHANOL VENDOR SHOP DRAWINGS FOR INSTRUMENTATION LOCATIONS AND I/O REQUIREMENTS.
 - ALL DEVICES SHOWN MUST FOLLOW PROPER WIRING AND INSTALLATION REQUIREMENTS FOR HAZARDOUS AREAS. REFER TO ELECTRICAL DRAWINGS AND SPECIFICATIONS FOR ALL AREA CLASSIFICATION REQUIREMENTS. REFER TO ELECTRICAL DRAWING E1.03
 - FINAL LOCATION OF TRUCK UNLOADING PANEL TO BE VERIFIED ON-SITE. LOCATION OF PANEL TO BE LOCATED APPROX. 7 METERS FROM UNLOADING AREA TO AVOID VAPOURS AND/OR SPILLAGE FROM METHANOL TRUCK. PANEL TO BE RATED FOR CLASS 1, ZONE 2 AND WEATHERPROOF.
 - REFER TO PROCESS DRAWING P17.01 FOR STORAGE TANK DETAILS. CONTRACTOR TO CORRIDNATE WITH STORAGE TANK SUPPLIER LOCATIONS FOR LEVEL MEASUREMENT DEVICES.
 - INSTRUMENT LOCATIONS ARE INTENDED TO BE FOR ESTIMATING PURPOSES ONLY. EXACT LOCATIONS WILL BE DETERMINED ON-SITE DURING CONSTRUCTION.

<p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007</p>	B.M. ELEV.	<p>A Tyco International Ltd. Company</p>	ENGINEER'S SEAL	<p>THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION</p>					
			DESIGNED BY: CD		CHECKED BY: BL	ORIGINAL SIGNED BY: P. STRYK			
			DRAWN BY: SRP		APPROVED BY: JEH	2006/05/15			
			SCALE: AS NOTED		RELEASED FOR CONSTRUCTION BY: K. MARTENS	CONSULTANT DRAWING NO. 11.07			
	NO. REVISIONS	DATE	DATE	DATE	2006/03/29	DATE	2006/05/15	NEWPC CENTRATE NUTRIENT TREATMENT NITROGEN REMOVAL FACILITY	CITY FILE NUMBER
								INSTRUMENTATION METHANOL DOSING TANKS INSTALLATION PLAN	SHEET OF
									CITY DRAWING NUMBER