



THIS DRAWING IS BASED ON CITY OF WINNIPEG DRAWING NUMBER 1-0101W-G-A0314-001-03D

- NOTES:**
- SUPPLIED AND INSTALLED UNDER A SEPARATE CONTRACT.
  - SUPPLIED BY THE CITY OF WINNIPEG. INSTALLED BY THE CONTRACTOR.

■ = DENOTES NEW EQUIPMENT TO BE SUPPLIED AND INSTALLED BY CONTRACTOR.

EQUIP. NO.: C942-P  
 TYPE: SELF PRIMING PUMP  
 CAPACITY: 13.2 m<sup>3</sup>/hr  
 HEAD: 60 kPa  
 POWER: 0.56 kW

<p>Certificate of Authorization                  Earth Tech Canada Inc.                  No. 730 Expiry: April 30, 2007</p>	<p>A Tyco International Ltd. Company</p>		ENGINEER'S SEAL ORIGINAL SIGNED BY J.E. HUTCHISON 2006/05/15		<p>THE CITY OF WINNIPEG                  WATER AND WASTE DEPARTMENT                  ENGINEERING DIVISION</p>	
	DESIGNED BY: LW/CD	CHECKED BY: SB/PS	NEWPCC CENTRATE NUTRIENT TREATMENT NITROGEN REMOVAL FACILITY			
	DRAWN BY: GLG	APPROVED BY: JEH	CITY FILE NUMBER SHEET OF			
	SCALE: NONE	RELEASED FOR CONSTRUCTION BY: K. MARTENS	CITY DRAWING NUMBER			
00 ISSUED FOR TENDER	06/05/15	GLG	DATE: 2006/03/08	DATE: 2006/05/23	CONSULTANT DRAWING NO. P22.01	PROCESS DEWATERING (CENTRIFUGE DISCHARGE PIPING) PROCESS & INSTRUMENTATION DIAGRAM