



- NOTES:**
- REMOVE EXISTING PIPING AND FITTINGS AND INSTALL NEW PIPING AND FITTINGS AS SHOWN.
 - BRISTOL SAMPLER AND REFRIGERATOR SUPPLIED BY THE CITY AND INSTALLED BY CONTRACTOR. SUPPLY AND INSTALL AIR LINE TO BRISTOL SAMPLER FROM NEAREST EXISTING AIR LINE. SUPPLY AND INSTALL ALL ELECTRICAL AND CONTROL WIRING.
 - 50x50mm AIR/VACUUM VALVE, G.A. INDUSTRIES FIG 935 TYP. 2. OR APPROVED EQUAL. SEE STANDARD DETAIL 735. PROVIDE DRAINS AND FLUSHING CONNECTORS TO THE AIR RELEASE VALVES. PROVIDE DRAINS TO NEAREST FLOOR DRAIN.

<p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007</p>	B.M. ELEV.	<p>A Tyco International Ltd. Company</p>	ENGINEER'S SEAL	<p>THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION</p>	
			DESIGNED BY: LW		ORIGINAL SIGNED BY: J.E. HUTCHISON
			CHECKED BY: SB		2006/05/15
			APPROVED BY: JEH		CONSULTANT DRAWING NO. P3.02
	SCALE: AS NOTED	RELEASED FOR CONSTRUCTION BY: K. MARTENS	NEWCC CENTRATE NUTRIENT TREATMENT NITROGEN REMOVAL FACILITY	CITY FILE NUMBER	
	NO. REVISIONS	DATE BY DATE	2006/01/24	2006/05/15	SHEET OF
	00 ISSUED FOR TENDER	06/05/15	GLG		CITY DRAWING NUMBER
					PROCESS PIPING CONNECTIONS AND DETAILS SHEET 1