



EQUALIZATION TANK
C300

- EQUIP. NO.: C330-P
TYPE: SUBMERSIBLE PUMP
CAPACITY: 290 m³/hr
HEAD: 11 m
POWER: 23.9 kW
- EQUIP. NO.: C340-P
TYPE: SUBMERSIBLE PUMP
CAPACITY: 290 m³/hr
HEAD: 11 m
POWER: 23.9 kW
- EQUIP. NO.: C952-P
TYPE: SUBMERSIBLE PUMP
CAPACITY: 10.8 m³/hr
HEAD: 10.5 m
POWER: 1.2 kW
- EQUIP. NO.: C962-AC/AD
TYPE: AIR COMPRESSOR + DRYER
CAPACITY: 3.4 m³/hr
PRESSURE: 690 kPa
POWER: 0.37 kW

NOTES:
1. C350-FIT LOCATED IN GALLERY 2A.
2. SUPPLIED BY THE CITY, INSTALLED BY CONTRACTOR.

 Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007	B.M. ELEV.	 A Tyco International Ltd. Company	ENGINEER'S SEAL	 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	
			DESIGNED BY: YL/CD		ORIGINAL SIGNED BY: J.E. HUTCHISON
			DRAWN BY: SRP		APPROVED BY: JEH
			SCALE: NONE		RELEASED FOR CONSTRUCTION BY: K. MARTENS
	00 ISSUED FOR TENDER 06/05/15 CD	DATE: 2006/01/16	DATE: 2006/05/15	NEWPCC CENTRATE NUTRIENT TREATMENT NITROGEN REMOVAL FACILITY PROCESS EQUALIZATION TANK PROCESS & INSTRUMENTATION DIAGRAM	
	NO. REVISIONS	DATE	DATE	CITY FILE NUMBER SHEET OF CITY DRAWING NUMBER	