



SITE PLAN
SCALE: 1:250

DRAWING NOTES	
①	CONNECT VALVE ACTUATOR POWER AND CONTROLS.
②	600V POWER CONDUCTOR FOR EXISTING ACTUATOR TO BE DISCONNECTED AND INSTALLED IN NEW JUNCTION BOX. NEW POWER CONDUCTOR TO BE INSTALLED FROM JUNCTION BOX TO NEW ACTUATOR OUTSIDE. CONTROL CONDUCTOR FOR EXISTING ACTUATOR TO BE DISCONNECTED AND INSTALLED IN NEW CONTROLS JUNCTION BOX. NEW CONDUCTOR TO BE INSTALLED FROM NEW CONTROLS JUNCTION BOX TO NEW ACTUATOR OUTSIDE.

<p>APECM Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007</p>	B.M. ELEV.	<p>Frederickson Cooper ARCHITECTS</p>	<p>EarthTech A Tyco International Ltd. Company</p>	ENGINEER'S SEAL	<p>THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION</p>		
				DESIGNED BY: BLM		CHECKED BY: PS	ORIGINAL SIGNED BY: P. STRYK
				DRAWN BY: ERC		APPROVED BY: AHL	2007/03/19
				SCALE: AS SHOWN		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI	CONSULTANT DRAWING NO. WD-E0001
	00 ISSUED FOR TENDER 07/03/19 ERC				WATER TREATMENT PLANT DEACON BOOSTER PUMP STATION UPGRADE	CITY FILE NUMBER	
	NO. REVISIONS	DATE BY	DATE	DATE	ELECTRICAL SITE PLAN SCHEDULES AND DETAILS	SHEET OF	
		2006/12/06	2007/03/19			CITY DRAWING NUMBER	
						1-06010-A-E0001-001-000	